



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17290-73-1846
State Number
23101

EQUIPMENT INSPECTED

State Number: 23101	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 4	Installed: 12/28/2005	Rope Size: .
Volts: 208	Complied: 12/28/2005	Entrances: 1
OWNER	OCCUPANT	
FIRST REFORMED UNITED CHURCH	FIRST REFORMED UNITED CHURCH	
513 W FRONT ST	513 W FRONT ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 10/17/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.
- 2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 12/16/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: fruce@bellsouth.net

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST REFORMED UNITED CHURCH
513 W FRONT ST
BURLINGTON, NC, 27215