

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 17292-76-1581 State Number 26000

	EQUI	IPMENT INSPECTED		
State Number: 26000	Type of Unit: Passer	nger F	loor to Floor: 1 to 3	
Capacity: 2500	Manuf: TKE	•	Speed: 150	
Landings: 3	Installed: 12/03/200	8 R	Rope Size:	
Volts: 480	Complied:	E	Entrances: 1	
OWNER		OCCUPANT		
PHOENIX RISING OF ASH	E CO.	HOLIDAY INN EXPR	ESS	
203 HAMPTON PLACE CC	URT	203 HAMPTON PLACE		
WEST JEFFERSON, NC, 28	694	W JEFFERSON, NC, 2	28694	
	INSPEC	CTION INFORMATION		
Inspection Date 10/19/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE 5
		VIOLATIONS		
spaces and control 8.6.4.9 Clean the car top.	nergency Phone in working order.	ation of the elevator shall not be stored in	n machinery spaces, mach	ine rooms, control
Items must be corrected by	v: 12/18/2017 writing on Corrected Violations Form when	the following corrections have been made	de in order to bring your e	equipment into
complainace with current code	S.	-		
Violations pointed out to: John	1 Moretz 336-846-4000	Ins	pector	
THIS IS NOT AN INVOICE	To make changes to the invoice mailing	g address please call: 919-733-0372		
	An invoice will be mailed to:	PHOENIX RISING OF ASHE CO. 203 HAMPTON PLACE COURT WEST JEFFERSON, NC. 28694		