



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17293-76-1985
State Number
18561

EQUIPMENT INSPECTED

State Number: 18561	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: KONE	Speed: 100
Landings: 2	Installed: 06/03/1999	Rope Size:
Volts: 480	Complied: 06/10/1999	Entrances: 2
OWNER	OCCUPANT	
JEFFERSON LAND LLC	JEFFERSON LANDING	
PO BOX 110	184 WEST LANDING DR.	
JEFFERSON, NC, 28640	JEFFERSON, NC, 28640	

INSPECTION INFORMATION

Inspection Date 10/20/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

VIOLATIONS

- 8.6.11.1 Provide a monthly log on the results of the Phase I and Phase II operations.
- 2.2.5.1 Place the pit lights in working order. 100 lx or 10 fc @ the pit floor.
- 2.29.1 Assign identification numbers or letters to the equipment where required. "Do Not Use In Case Of Fire" sign needed at first floor
- 8.6.1.6.5 Provide a NBCC Class ABC fire extinguisher convenient to the access door in the machine room / space.
- 2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 12/19/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Sonny 336-982-4494

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JEFFERSON LAND LLC
PO BOX 110
JEFFERSON, NC, 28640