



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17296-65-3446
State Number
29118

EQUIPMENT INSPECTED

State Number: 29118	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: VERT EXP	Speed: 80
Landings: 2	Installed: 07/16/2014	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
COUNTY OF AVERY JAIL ANNEX	AVERY COUNTY COURTHOUSE	
P.O.BOX 640	200 MONTEZUMA STREET	
NEWLAND, NC, 28657	NEWLAND, NC, 28657	

INSPECTION INFORMATION

Inspection Date 10/23/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Joe Trivette 828-387-0072

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COUNTY OF AVERY JAIL ANNEX
P.O.BOX 640
NEWLAND, NC, 28657