



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17296-76-0825**  
State Number  
**25849**

#### EQUIPMENT INSPECTED

State Number: <b>25849</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3000	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 06/30/2008	Rope Size:
Volts: 208	Complied: 06/30/2008	Entrances: 1
OWNER	OCCUPANT	
JEFFERSON LANDING	BIRKDALE VILLAS	
P O BOX 110	165 BIRKDALE COURT	
JEFFERSON, NC, 28640	JEFFERSON, NC, 28640	

#### INSPECTION INFORMATION

Inspection Date 10/23/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

#### VIOLATIONS

- 2.29.1 Assign identification numbers or letters to the equipment where required. Elevator machine room door needs a sign "Elevator Room"
- 8.6.11.1 Provide a monthly log on the results of the Phase I and Phase II operations.
- 2.7.9.1 Place the machine room or space lights in working order. Fluorescent lights need to be protected
- 8.6.4.7 Remove the water from the pit floor and take steps to prevent its re-entry.

Items must be corrected by: 12/22/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: 336-246-6794

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JEFFERSON LANDING  
P O BOX 110  
JEFFERSON, NC, 28640