



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17298-75-5414**  
State Number  
**966**

EQUIPMENT INSPECTED

State Number: <b>966</b>	Type of Unit: Passenger	Floor to Floor: B to 4
Capacity: 2000	Manuf: OTIS	Speed: 100
Landings: 5	Installed: 02/20/1948	Rope Size: 1/2
Volts: 220	Complied: 09/17/2003	Entrances: 1
OWNER	OCCUPANT	
35 PATTON CONDO ASSOCIATION	35 PATTON CONDO ASSOCIATION	
P.O.BOX 1021	35 PATTON AVE	
ASHEVILLE, NC, 28802	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 10/25/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

8.6.4.9	Clean the oil from the car top.
2.24.8.6	Seal the drive machine oil leaks.
8.6.1.4.1	Provide an updated Firefighters Emergency Operation log. (Monthly)
8.6.1.6.5	Provide a class ABC fire extinguisher in the machinery space.(Out of date.)

Items must be corrected by: 12/24/2017

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Bill Palas 828-691-7194

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

35 PATTON CONDO ASSOCIATION  
P.O.BOX 1021  
ASHEVILLE, NC, 28802