



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17303-48-2695**  
State Number  
**14615**

EQUIPMENT INSPECTED

State Number: <b>14615</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 2	Installed: 09/17/1992	Rope Size:
Volts: 480	Complied: 10/01/1992	Entrances: 1
OWNER	OCCUPANT	
SMITHFIELD PACKING	CAROLINA FOOD PROCESSOR	
1911 S. CHURCH ST.	NC HWY. 87S	
SMITHFIELD, VA, 23430	TARHEEL, NC, 28392	

INSPECTION INFORMATION

Inspection Date 10/30/2017	Type Inspection Not Inspected	Certificate Status Not Issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------------	----------------------------------	--------------------------	------------------

9

VIOLATIONS

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MGMT.

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SMITHFIELD PACKING  
1911 S. CHURCH ST.  
SMITHFIELD, VA, 23430