



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17303-48-3048
State Number
14616

EQUIPMENT INSPECTED

State Number: 14616	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 12000	Manuf: OTIS	Speed: 75
Landings: 3	Installed: 08/17/1992	Rope Size:
Volts: 480	Complied: 06/16/2003	Entrances: 1
OWNER	OCCUPANT	
SMITHFIELD PACKING	CAROLINA FOOD PROCESSOR	
1911 S. CHURCH ST.	NC HWY 87S	
SMITHFIELD, VA, 23430	TAR HEEL, NC, 28392	

INSPECTION INFORMATION

Inspection Date 10/30/2017	Type Inspection Compliance	Certificate Status Prev Issued	Inspector 48 - Martin	County BLADEN
-------------------------------	-------------------------------	-----------------------------------	--------------------------	------------------

9

VIOLATIONS

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MGMT.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SMITHFIELD PACKING
1911 S. CHURCH ST.
SMITHFIELD, VA, 23430