N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17305-48-1017
State Number
21075

EQUIPMENT INSPECTED

State Number: **21075**
Capacity: 2100
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: SCHINDLER
Installed: 06/20/2002
Complied: 06/24/2002

Floor to Floor: 1 to 3
Speed: 100
Rope Size: .
Entrances: 1

OWNER
OCEAN GREENS CONDO ASSOC
77 FOXFIRE DR #6
CASWELL BEACH, NC, 28465

OCCUPANT
OCEAN GREEN CONDO #6
75-78 FOX FIRE TRACE
CASWELL BEACH, NC, 28465

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
11/01/2017	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

Elevator Name: #6

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
OCEAN GREENS CONDO ASSOC
77 FOXFIRE DR #6
CASWELL BEACH, NC, 28465