N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17305-65-139
State Number
13317

EQUIPMENT INSPECTED

State Number: **13317**
Capacity: 2100
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: SOUTHERN
Installed: 08/23/1989
Complied: 08/23/1989

Floor to Floor: 1 to 2
Speed: 100
Rope Size: 0
Entrances: 1

OWNER
GRANDFATHER COUNTRY CLUB
2120 HWY.105 NORTH
LINVILLE, NC, 28646

OCCUPANT
GRANDFATHER COUNTRY CLUB
1225 HWY.105 NORTH
LINVILLE, NC, 28646

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
11/01/2017	Routine	Re-issued	65 - Kelley	AVERY

6

VIOLATIONS

8.6.1.6.5 Provide a class ABC fire extinguisher in the machinery space. Needs service and updated tag.
2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 11/11/2017

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: David McGuire 828-898-4531

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
GRANDFATHER COUNTRY CLUB
2120 HWY.105 NORTH
LINVILLE, NC, 28646