



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17310-48-1925**  
State Number  
**24260**

#### EQUIPMENT INSPECTED

State Number: <b>24260</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 50
Landings: 4	Installed: 11/07/2006	Rope Size: 0
Volts: 240	Complied: 11/07/2006	Entrances: 1
OWNER	OCCUPANT	
OCEAN WALK HOA	OCEANWALK CONDOS #7	
C/O GO PROPERTY MGMT-G OWEN	105 SE 58TH STREET	
WILMINGTON, NC, 28405	OAK ISLAND, NC, 28465	

#### INSPECTION INFORMATION

Inspection Date 11/06/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

#### VIOLATIONS

2.27.1.1.1	Place the in-car Emergency Phone in working order. [SAME AS LAST YR.]
2.2.2.4	Place the sump pump in working order. RUNOFF PIPE HAS A HOLE IN IT. [SAME AS LAST YR.]
8.6.4.7	Clean the pit and the pit equipment.

Items must be corrected by: 12/06/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN WALK HOA  
C/O GO PROPERTY MGMT-G OWEN  
WILMINGTON, NC, 28405