



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17311-48-2732
State Number
15582

EQUIPMENT INSPECTED

State Number: 15582	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 12000	Manuf: OTIS	Speed: 75
Landings: 2	Installed: 11/23/1994	Rope Size:
Volts: 480	Complied: 12/05/1994	Entrances: 1
OWNER	OCCUPANT	
SMITHFIELD PACKING	CAROLINA FOOD PROCESSORS	
1911 S. CHURCH ST.	NC HWY. 87S	
SMITHFIELD, VA, 23430	TARHEEL, NC, 28392	

INSPECTION INFORMATION

Inspection Date 11/07/2017	Type Inspection Compliance	Certificate Status Issued	Inspector 48 - Martin	County BLADEN
-------------------------------	-------------------------------	------------------------------	--------------------------	------------------

9

VIOLATIONS

Elevator Name: # 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DENNIS PARKS

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SMITHFIELD PACKING
1911 S. CHURCH ST.
SMITHFIELD, VA, 23430