



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17311-76-1050
State Number
19072

EQUIPMENT INSPECTED

State Number: 19072	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 2	Installed: 12/19/2000	Rope Size:
Volts: 208	Complied: 12/19/2000	Entrances: 1
OWNER	OCCUPANT	
BALD MOUNTAIN BAPTIST CH	BALD MOUNTAIN BAPTIST CH	
1460 BALD MTN RD	1460 BALD MTN RD	
W JEFFERSON, NC, 28640	W JEFFERSON, NC, 28640	

INSPECTION INFORMATION

Inspection Date 11/07/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

VIOLATIONS

- 2.29.1 Assign identification numbers or letters to the equipment where required. "Do Not Use In Cases Of Fire" signs missing
- 2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 01/06/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Bald Mountain Baptist 336-877-1550

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BALD MOUNTAIN BAPTIST CH
1460 BALD MTN RD
W JEFFERSON, NC, 28640