



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17311-76-4467
State Number
18071

EQUIPMENT INSPECTED

State Number: 18071	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 10/28/1998	Rope Size:
Volts: 480	Complied: 10/28/1998	Entrances: 1
OWNER	OCCUPANT	
G.E. AVIATION	G.E. AVIATION	
400 PROFESIONAL DR.	400 PROFESIONAL DR.	
WEST JEFFERSON, NC, 28694	WEST JEFFERSON, NC, 28694	

INSPECTION INFORMATION

Inspection Date 11/07/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

VIOLATIONS

- 2.7.9.1 Place the machine room or space lights in working order. Flourscent lights need to be protected
- 8.6.4.8.2 Articles or materials not necessary for the maintenace or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.
- 2.7.3.4.1 Provide a self closing self-locking machine room / space door.

Items must be corrected by: 01/06/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Bryan 336-846-1445

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

G.E. AVIATION
400 PROFESIONAL DR.
WEST JEFFERSON, NC, 28694