



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17311-79-0586
State Number
9274

EQUIPMENT INSPECTED

State Number: 9274	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: OTIS	Speed: 125
Landings: 2	Installed: 02/15/1979	Rope Size:
Volts: 208	Complied: 02/11/2002	Entrances: 1

OWNER
CITY OF WASHINGTON
PO BOX 1988
WASHINGTON, NC, 27889

OCCUPANT
E PETERSON BLDG
310 W MAIN ST
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date 11/07/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 79 - Cumberland	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	------------------------------	--------------------

7

VIOLATIONS

5.1.21.1	Place the car alarm bell in working order. Minimum level of 80 dBA.
2.27.1.1.1	Place the in-car Emergency Phone in working order.
8.6.4.8	Clean the machine room and the machine room equipment.

Items must be corrected by: 01/06/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office manager

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF WASHINGTON
PO BOX 1988
WASHINGTON, NC, 27889