



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17317-48-4461
State Number
29324

EQUIPMENT INSPECTED

State Number: 29324	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: ANER CRESC	Speed: 100
Landings: 2	Installed: 08/28/2015	Rope Size:
Volts: 208	Complied:	Entrances: 2
OWNER	OCCUPANT	
JIM FISH	BRUNSWICK SENIOR CONDOS	
3620 EXPRESS DRIVE	3620 EXPRESS DRIVE	
SHALLOTTE, NC, 28470	SHALLOTTE, NC, 28470	

INSPECTION INFORMATION

Inspection Date 11/13/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.19.2 (b) Provide the annual no load test.

Items must be corrected by: 12/13/2017

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MGMT.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JIM FISH
3620 EXPRESS DRIVE
SHALLOTTE, NC, 28470