



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17317-65-0349
State Number
28117

EQUIPMENT INSPECTED

State Number: 28117	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: TKE	Speed: 100
Landings: 3	Installed: 04/05/2012	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
AVERY CO HUMANE SOCIETY INC	AVERY CO HUMANE SOCIETY SHELTER/OFFICE	
P O BOX 1213	279 NEW VALE ROAD	
NEWLAND, NC, 28657	NEWLAND, NC, 28657	

INSPECTION INFORMATION

Inspection Date 11/13/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

2.2.5.1 Place the pit lights in working order. 100 lx or 10 fc @ the pit floor.

Items must be corrected by: 01/12/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Charlene Calhoun 828-733-2333

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY CO HUMANE SOCIETY INC
P O BOX 1213
NEWLAND, NC, 28657