



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17320-73-0967
State Number
10530

EQUIPMENT INSPECTED

State Number: 10530	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 08/09/1983	Rope Size:
Volts: 200	Complied: 08/17/1983	Entrances: 1
OWNER	OCCUPANT	
TWIN LAKES CENTER	TWIN LAKES CENTER	
100 WADE COBLE DR	100 WADE COBLE DR	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 11/16/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 8.6.1.6.5 Provide a class ABC fire extinguisher in the machinery space. Current one has expired
- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.
- 8.6 Provide in case of fire sign on each landing

Items must be corrected by: 01/15/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Marty Seamster 336 5381598

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

TWIN LAKES CENTER
100 WADE COBLE DR
BURLINGTON, NC, 27215