N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17320-73-1984
State Number
14805

EQUIPMENT INSPECTED

State Number: **14805**
Capacity: 2100
Landings: 2
Volts: 200

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 01/08/1993
Complied: 01/11/1993

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
TWIN LAKES CENTER
100 WADE COBLE DR
BURLINGTON, NC, 27215

OCCUPANT
TWIN LAKES CENTER
100 WADE COBLE DR
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
11/16/2017	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

2.27.1.1.1	Place the in-car Emergency Phone in working order.
8.6	Provide in case of fire sign at each landing

Items must be corrected by: 01/15/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Marty Seamster 336 538 1598 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
TWIN LAKES CENTER
100 WADE COBLE DR
BURLINGTON, NC, 27215