



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17320-73-4113
State Number
18249

EQUIPMENT INSPECTED

State Number: 18249	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 3	Installed: 09/13/1999	Rope Size:
Volts: 208	Complied: 09/13/1999	Entrances: 2
OWNER	OCCUPANT	
TWIN LAKES CENTER	TWIN LAKES CENTER	
100 WADE COBLE DR	100 WADE COBLE DR	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 11/16/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6 Provide in case of fire sign at each landing

Items must be corrected by: 01/15/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Marty Seamster 336 538 1598

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

TWIN LAKES CENTER
100 WADE COBLE DR
BURLINGTON, NC, 27215