



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17324-75-2797
State Number
11371

EQUIPMENT INSPECTED

State Number: 11371	Type of Unit: Passenger	Floor to Floor: B to 4
Capacity: 2500	Manuf: ASHEVILLE	Speed: 135
Landings: 5	Installed: 12/22/1986	Rope Size:
Volts: 208	Complied: 01/05/2007	Entrances: 1

OWNER

11 NORTH MARKET ST. BLDG.
11 N. MARKET STREET
ASHEVILLE, NC, 28801

OCCUPANT

11 NORTH MARKET ST. BLDG.
11 N. MARKET STREET
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 11/20/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

8.6.10.2 Keys required for access, operation, inspection, maintenance, repair, and emergency access shall be made available only to qualified elevator personnel.

Items must be corrected by: 01/19/2018

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: David Boeke 828-771-2546

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

11 NORTH MARKET ST. BLDG.
11 N. MARKET STREET
ASHEVILLE, NC, 28801