



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17326-73-4527
State Number
29537

EQUIPMENT INSPECTED

State Number: 29537	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 1400	Manuf: CUSTOM ELEV INC	Speed: 30
Landings: 3	Installed: 08/04/2014	Rope Size:
Volts: 480	Complied: 08/04/2014	Entrances: 2

OWNER
FIRST BAPTIST CHURCH
508 APPLE STREET
BURLINGTON, NC, 27215

OCCUPANT
FIRST BAPTIST CHURCH
508 APPLE STREET
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 11/22/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6 Place smoke detector in machine room in proper working order

Items must be corrected by: 01/21/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Frankie 336 227 2542

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST BAPTIST CHURCH
508 APPLE STREET
BURLINGTON, NC, 27215