



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17326-73-4838
State Number
12512

EQUIPMENT INSPECTED

State Number: 12512	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: MELO	Speed: 150
Landings: 3	Installed: 05/02/1988	Rope Size:
Volts: 480	Complied: 01/27/1997	Entrances: 1

OWNER
CAPITAL BANK
333 FAYETTEVILLE STREET
RALEIGH, NC, 27601

OCCUPANT
CAPITAL BANK
445 S MAIN
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 11/22/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 8.6 Provide in case of fire sign at each landing. Missing sign on 1st and 2nd floor
- 8.6 Replace jack packing

Items must be corrected by: 01/21/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Aashley Foster 336 506 1687

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAPITAL BANK
333 FAYETTEVILLE STREET
RALEIGH, NC, 27601