N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17334-73-2464
State Number
15502

EQUIPMENT INSPECTED

State Number: **15502**
Capacity: 4500
Landings: 4
Volts: 460

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 07/19/1994
Complied: 08/30/1994

Floor to Floor: 1 to 4
Speed: 180
Rope Size:
Entrances: 1

OWNER
KOURY PROPERTIES CENTER
PO BOX 850
BURLINGTON, NC, 27215

OCCUPANT
KOURY MANAGEMENT
3060 S CHURCH ST
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
11/30/2017	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

8.6 Provide in case of fire sign at each landing
8.6 Replace jack packing

Items must be corrected by: 01/29/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Steve Gentry 336 213 4438 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
KOURY PROPERTIES CENTER
PO BOX 850
BURLINGTON, NC, 27215