



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17334-73-2515
State Number
14233

EQUIPMENT INSPECTED

State Number: 14233	Type of Unit: Passenger	Floor to Floor: B to 3
Capacity: 4000	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 4	Installed: 08/22/1991	Rope Size:
Volts: 460	Complied: 08/22/1991	Entrances: 1
OWNER	OCCUPANT	
KOURY PROPERTIES CENTER	KOURY MANANGMENT	
PO BOX 850	3060 S CHURCH ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 11/30/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6 Place in case of fire sign at each landing

Items must be corrected by: 01/29/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Steve Gentry 336 213 4438

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

KOURY PROPERTIES CENTER
PO BOX 850
BURLINGTON, NC, 27215