



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17335-76-5724
State Number
19198

EQUIPMENT INSPECTED

State Number: 19198	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 12/08/2000	Rope Size: 0
Volts: 480	Complied: 12/14/2000	Entrances: 1
OWNER	OCCUPANT	
AVERY COUNTY SCHOOLS	NEW CROSSNORE ELEMENTARY	
775 CRANBERRY STREET	1000 WALT CLARK ROAD	
NEWLAND, NC, 28657	CROSSNORE, NC, 28616	

INSPECTION INFORMATION

Inspection Date 12/01/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County AVERY
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

6

VIOLATIONS

- 8.6.11.1 Provide a monthly log on the results of the Phase I and Phase II operations.
- 2.27.1.1.1 Place the in-car Emergency Phone in working order. Phone isn't answered with the 110 power off
- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.

Items must be corrected by: 01/30/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Matthew Bentlt 828-737-7204

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY COUNTY SCHOOLS
775 CRANBERRY STREET
NEWLAND, NC, 28657