



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17345-73-1739
State Number
7033

EQUIPMENT INSPECTED

State Number: 7033	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 200
Landings: 4	Installed: 11/11/1971	Rope Size: 1/2
Volts: 240	Complied: 12/14/1971	Entrances: 1
OWNER	OCCUPANT	
500 S MAIN GLP LLC	WELLS FARGO BLDG - 3351	
% CBRE	500 S MAIN ST	
GREENSBORO, NC, 27409	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 12/11/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.27.1.1.1	Place the in-car Emergency Phone in working order.
8.6	Place in case of fire sign at each landing

Items must be corrected by: 02/09/2018

Elevator Name: 3661x code

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Stephanie Farra stephanie.farra@wellsfargo.com

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

500 S MAIN GLP LLC
% CBRE
GREENSBORO, NC, 27409