



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17347-48-5149
State Number
23791

EQUIPMENT INSPECTED

State Number: 23791	Type of Unit: Passenger	Floor to Floor: 1 to 5
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 5	Installed: 04/26/2006	Rope Size: 0
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
CAMS	THE PRESERVE BUILDING #2 - CAR#2	
1630 MILITARY CUTOFF RD.	2100 MARSH GROVE LANE	
WILMINGTON, NC, 28403	OAK ISLAND, NC, 28465	

INSPECTION INFORMATION

Inspection Date 12/13/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.

Items must be corrected by: 01/12/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: TODD STREETER

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAMS
1630 MILITARY CUTOFF RD.
WILMINGTON, NC, 28403