



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17348-73-1022**  
State Number  
**29079**

EQUIPMENT INSPECTED

State Number: <b>29079</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 5000	Manuf: TKE	Speed: 125
Landings: 2	Installed: 11/08/2013	Rope Size:
Volts: 460	Complied:	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE REGIONAL MEDICAL CENTER	ALAMANCE REGIONAL MEDICAL CENTER CAR 3	
1240 HUFFMAN MILL ROAD	1240 HUFFMAN MILL ROAD	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 12/14/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.7 Clean the pit and the pit equipment.

Items must be corrected by: 02/12/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jim Canada

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE REGIONAL MEDICAL CENTER  
1240 HUFFMAN MILL ROAD  
BURLINGTON, NC, 27215