N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17352-48-0187
State Number
22646

EQUIPMENT INSPECTED

State Number: **22646**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 2	Installed: 04/27/2005	Rope Size:
Volts: 208	Complied: 04/27/2005	Entrances: 1

OWNER
BRUNSWICK MEDICAL CAMPUS CONDO ASSOC
1430 COMMONWEALTH DR STE 102
WILMINGTON, NC, 28403

OCCUPANT
BRUNSWICK MEDICAL CAMPUS
346 OCEAN HIGHWAY WEST
SUPPLY, NC, 28462

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
12/18/2017	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.19.2 (b) Provide the annual no load test.

Items must be corrected by: 01/17/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BRUNSWICK MEDICAL CAMPUS CONDO ASSOC
1430 COMMONWEALTH DR STE 102
WILMINGTON, NC, 28403