



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17352-73-0959
State Number
28808

EQUIPMENT INSPECTED

State Number: 28808	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 3500	Manuf: TKE	Speed: 125
Landings: 4	Installed: 07/24/2014	Rope Size:
Volts: 460	Complied: 07/24/2014	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	ELON GLOBAL RESIDENCE HALLS BLDG 2	
CAMPUS BOX 2060	103 PHOENIX DRIVE	
ELON, NC, 27244	EKON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 12/18/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy Elon 336 380 6126

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
CAMPUS BOX 2060
ELON, NC, 27244