



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17352-73-3423**  
State Number  
**28459**

EQUIPMENT INSPECTED

State Number: <b>28459</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: TKE	Speed: 125
Landings: 2	Installed: 01/07/2013	Rope Size:
Volts: 460	Complied: 01/07/2013	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	ELON GLOBAL DINING HALL ELEV 1	
ELON CAMPUS	ELON UNIVERSITY	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 12/18/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy Elon 336 380 6126

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY  
ELON CAMPUS  
ELON, NC, 27244