N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17352-73-4323
State Number
28460

EQUIPMENT INSPECTED

State Number: **28460**
Capacity: 4500
Landings: 2
Volts: 460

Type of Unit: Passenger
Manuf: TKE
Installed: 01/07/2013
Complied: 01/07/2013

Floor to Floor: 1 to 2
Speed: 125
Rope Size:
Entrances: 1

OWNER
ELON UNIVERSITY
ELON CAMPUS
ELON, NC, 27244

OCCUPANT
ELON GLOBAL DINING HALL ELEV 2
ELON UNIVERSITY
ELON, NC, 27244

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
12/18/2017	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

2.14.7.1.2 Place the passenger cab interior lights in working order. 50 lx or 5 fc @ the cab floor.

Items must be corrected by: 02/16/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Jeremy Elon 336 380 6126 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ELON UNIVERSITY
ELON CAMPUS
ELON, NC, 27244