



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17352-75-4879
State Number
23783

EQUIPMENT INSPECTED

State Number: 23783	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: IECA	Speed: 100
Landings: 3	Installed: 03/13/2006	Rope Size: .
Volts: 208	Complied:	Entrances: 1

OWNER

ASHEVILLE BOARD OF REALTORS
37 MONTFORD AVE
ASHEVILLE, NC, 28801

OCCUPANT

ASHEVILLE BOARD OF REALTORS
37 MONTFORD AVE
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 12/18/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Brian Wooding 828-255-8505

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BOARD OF REALTORS
37 MONTFORD AVE
ASHEVILLE, NC, 28801