



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17353-48-1383
State Number
25220

EQUIPMENT INSPECTED

State Number: 25220	Type of Unit: Passenger	Floor to Floor: 1 to 5
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 5	Installed: 05/29/2008	Rope Size:
Volts: 208	Complied: 05/29/2008	Entrances: 1
OWNER		OCCUPANT
REGENCY CONDO HOA CAMS INC.		REGENCY CONDOS BLDG 2
1630 MILITARY CUTOFF RD. STE 108		915 SHORELINE DR. W
WILMINGTON, NC, 28403		SUNSET BEACH, NC, 28467

INSPECTION INFORMATION

Inspection Date 12/19/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK	10
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------	----

VIOLATIONS

- 6.1.6.9.1 A caution sign shall be located at the top and bottom landing of each escalator. The sign shall include the following: (a) Caution (b) Passengers Only (c) Hold Handrail (d) Attend children (e) avoid sides. [4TH FL]
- 2.27.1.1.1 Place the in-car Emergency Phone in working order. [2ND YR]

Items must be corrected by: 01/18/2018

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SHELBY

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
REGENCY CONDO HOA CAMS INC.
1630 MILITARY CUTOFF RD. STE 108
WILMINGTON, NC, 28403