N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17353-48-3817
State Number
25219

EQUIPMENT INSPECTED

State Number: **25219**
Capacity: 3500
Landings: 5
Volts: 206

Type of Unit: Passenger
Manuf: OTIS
Installed: 12/12/2007
Complied: 12/12/2007

Floor to Floor: 1 to 5
Speed: 150
Rope Size:
Entrances: 1

OWNER
REGENCY CONDO HOA CAMS INC.
1630 MILITARY CUTOFF RD. STE 108
WILMINGTON, NC, 28403

OCCUPANT
REGENCY CONDOS BLDG 1
915 SHORELINE DR. W.
SUNSET BEACH, NC, 28467

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
12/19/2017	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.8	Clean the machine room and the machine room equipment.
2.27.1.1.1	Place the in-car Emergency Phone in working order. [2ND YR]
8.6.4.7	Clean the pit and the pit equipment.

Items must be corrected by: 01/18/2018

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: SHELBY

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
REGENCY CONDO HOA CAMS INC.
1630 MILITARY CUTOFF RD. STE 108
WILMINGTON, NC, 28403