N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17353-48-5258
State Number
27879

EQUIPMENT INSPECTED

State Number: **27879**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 125
Landings: 2	Installed: 06/10/2011	Rope Size:
Volts: 208	Complied: 06/10/2011	Entrances: 1

OWNER	OCCUPANT
FIRST BANK	FIRST BANK BUILDING - SHALLOTTE
10 WATERFORD BUS CTR WAY	NC HWY 130 WHITEVILLE ROAD
BELVILLE, NC, 28451	SHALLOTTE, NC, 28459

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
12/19/2017	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

8.6.4.19.2 (b)	Provide the annual no load test.
2.14.7.1.2	Place the passenger cab interior lights in working order. 50 lx or 5 fc @ the cab floor.

Items must be corrected by: 01/18/2018

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: MGMT.

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
FIRST BANK
10 WATERFORD BUS CTR WAY
BELVILLE, NC, 28451