



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17353-73-0793
State Number
27611

EQUIPMENT INSPECTED

State Number: 27611	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: TKE	Speed: 100
Landings: 3	Installed: 08/03/2011	Rope Size:
Volts: 208	Complied: 08/04/2011	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	COLONNADES - KIVETTE HALL (C)	
100 CAMPUS DRIVE CB 2060	525 E PHOENIX DRIVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 12/19/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6 Place cartop light in working order

Items must be corrected by: 02/17/2018

Elevator Name: KIVITT HALL +

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy Elon 336 380 6126

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
100 CAMPUS DRIVE CB 2060
ELON, NC, 27244