



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17353-73-2113
State Number
24933

EQUIPMENT INSPECTED

State Number: 24933	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 2	Installed: 09/10/2007	Rope Size:
Volts: 480	Complied: 09/10/2007	Entrances: 1
OWNER	OCCUPANT	
R K HOSPITALITY GROUP	COLONNADES DINING (LOBBY)	
100 WOODLAKE PARKWAY	193 DALTON MCMICHAEL DR	
KINGS MOUNTAIN, NC, 28086	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 12/19/2017	Type Inspection Routine	Certificate Status Not Issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	----------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.5.14.1	Provide the annual relief valve and hydraulic system pressure test.
8.6	Machine room not to be used for storage
8.6	Place phase 2 operation in working order

Items must be corrected by: 02/17/2018

Elevator Name: COLLANADES lobby

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy Elon 336 380 6126

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

R K HOSPITALITY GROUP
100 WOODLAKE PARKWAY
KINGS MOUNTAIN, NC, 28086