



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17353-73-5845**  
State Number  
**23700**

EQUIPMENT INSPECTED

State Number: <b>23700</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 1	Installed: 06/22/2006	Rope Size: 0
Volts: 480	Complied: 06/22/2006	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	KOURY BUISNESS CENTERMARTHA,SPENCER,LOVE	
803 HAGGARD AVENUE	401 N O'KELLY AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 12/19/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 8.6.4.7 Clean the pit and the pit equipment.
- 2.14.7.1.3 Place the in-car emergency lights in working order. The auxillary lighting illumination shall not be less than 2 lx (0.2 fc) measured at any point between 48 in. and 35 in. above the car floor and approximately 12 in. centered horizontally in front o
- 5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.

Items must be corrected by: 02/17/2018

Elevator Name: MARTHA-SPENCER-LOVE

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Jeremy Elon 336 380 6126

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY  
803 HAGGARD AVENUE  
ELON, NC, 27244