



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17355-73-038
State Number
19631

EQUIPMENT INSPECTED

State Number: 19631	Type of Unit: Passenger	Floor to Floor: L to 3
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 3	Installed: 05/31/2001	Rope Size:
Volts: 480	Complied: 06/11/2001	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	RHODES STADIUM	
803 HAGGARD AVENUE	543 N WILLIAMSON AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 12/21/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

VIOLATIONS

- 8.6.4.7 Remove the water from the pit floor and take steps to prevent its re-entry.
- 2.27.1.1.1 Place the in-car Emergency Phone in working order.
- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.
- 8.6 Remove rust from pit channels and paint to prevent its return
- 8.6 Provide in case of fire sign at each landing
- 8.6 Take steps to eliminate mold in pit

Items must be corrected by: 02/19/2018

Elevator Name: RHODES STADIUM

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy Elon 336 380 6126

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
803 HAGGARD AVENUE
ELON, NC, 27244