



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18002-73-1999**  
State Number  
**25133**

EQUIPMENT INSPECTED

|                                    |                               |                        |
|------------------------------------|-------------------------------|------------------------|
| State Number: <b>25133</b>         | Type of Unit: Passenger       | Floor to Floor: 1 to 3 |
| Capacity: 2500                     | Manuf: TKE                    | Speed: 110             |
| Landings: 3                        | Installed: 08/22/2007         | Rope Size: 0           |
| Volts: 208                         | Complied: 08/22/2007          | Entrances: 2           |
| OWNER                              | OCCUPANT                      |                        |
| ACADEMIC VILLAGE - GRAY (POLI-SCI) | ELON UNIVERSITY ALAMANCE BLDG |                        |
| 304 EAST LEBANON AVENUE            | 107 E HAGGARD AVE             |                        |
| ELON, NC, 27244                    | ELON, NC, 27244               |                        |

INSPECTION INFORMATION

|                               |                            |                                 |                         |                    |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|
| Inspection Date<br>01/02/2018 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>73 - James | County<br>ALAMANCE |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|

1

VIOLATIONS

|          |   |
|----------|---|
| 8.6.4.7  | Clean the pit and the pit equipment.                                |
| 5.1.21.1 | Place the car alarm bell in working order. Minimum level of 80 dBA. |

Items must be corrected by: 03/03/2018

Elevator Name: ALAMANCE BDLG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy 3363806126

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ACADEMIC VILLAGE - GRAY (POLI-SCI)  
304 EAST LEBANON AVENUE  
ELON, NC, 27244