



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18002-73-2493
State Number
15165

EQUIPMENT INSPECTED

State Number: 15165	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 3500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 10/06/1994	Rope Size:
Volts: 460	Complied: 10/06/1994	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	MOSELY CENTER	
803 HAGGARD AVENUE	100 CAMPUS DR	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/02/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.13.1(i)	Place the door restrictor in proper working order.
2.14.7.1.2	Place the passenger cab interior lights in working order. 50 lx or 5 fc @ the cab floor.
8.6	Provide in case of fire sign at each landing

Items must be corrected by: 03/03/2018

Elevator Name: Mosley Center

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy 3363806126

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
803 HAGGARD AVENUE
ELON, NC, 27244