



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18002-73-3448
State Number
14909

EQUIPMENT INSPECTED

State Number: 14909	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 02/01/1994	Rope Size:
Volts: 480	Complied: 02/01/1994	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSTIY	KOURY CENTER (MAIN CONCOURSE)	
803 HAGGARD AVENUE	104 E HAGGARD AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/02/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.14.7.1.2	Place the passenger cab interior lights in working order. 50 lx or 5 fc @ the cab floor.
8.6	Place in case of fire sign at each landing

Items must be corrected by: 03/03/2018

Elevator Name: Koury cebter main concors

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Jeremy 3363806126

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSTIY
803 HAGGARD AVENUE
ELON, NC, 27244