



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18003-73-0788
State Number
18738

EQUIPMENT INSPECTED

State Number: 18738	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 110
Landings: 3	Installed: 11/17/1999	Rope Size:
Volts: 208	Complied: 11/17/1999	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	MOONEY ED BLDG	
803 HAGGARD AVE	200 E LEBANON AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/03/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 2.14.7.1.3 Place the in-car emergency lights in working order. The auxillary lighting illumination shall not be less than 2 lx (0.2 fc) measured at any point between 48 in. and 35 in. above the car floor and approximately 12 in. centered horizontally in front o
- 5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.
- 8.6 Place buffer springs in proper place in pit

Items must be corrected by: 03/04/2018

Elevator Name: Mooney BDLG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy 3363806126

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
803 HAGGARD AVE
ELON, NC, 27244