



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18003-73-2820
State Number
24654

EQUIPMENT INSPECTED

State Number: 24654	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 04/18/2007	Rope Size: 0
Volts: 208	Complied: 04/18/2007	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	ACADEMIC VILLAGE BELK -TEACHING-LEARNING	
803 HAGGARD AVENUE	360 ANTIOCH ROAD	
BURLINGTON, NC, 27244	ELON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 01/03/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.

Items must be corrected by: 03/04/2018

Elevator Name: Teaching-Learning

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy 3363806126

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
803 HAGGARD AVENUE
BURLINGTON, NC, 27244