



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18003-73-4325**  
State Number  
**18756**

EQUIPMENT INSPECTED

State Number: <b>18756</b>	Type of Unit: Passenger	Floor to Floor: B to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 110
Landings: 3	Installed: 08/04/2000	Rope Size:
Volts: 480	Complied: 08/04/2000	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	ELON UNIV / MCEWEN LIBRARY	
803 HAGGARD AVENUE	101 HAGGARD AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/03/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.2.2.6 Provide a sump pump cover, the cover shall be secure and level with the floor.

Items must be corrected by: 03/04/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy 3363806126

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY  
803 HAGGARD AVENUE  
ELON, NC, 27244