



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18003-73-4496
State Number
22176

EQUIPMENT INSPECTED

State Number: 22176	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 2	Installed: 05/20/2004	Rope Size: .
Volts: 208	Complied: 05/20/2004	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	ACADEMIC VILLAGE - GRAY (POLI-SCI)	
803 HAGGARD AVE	304 EAST LEBANON AVENUE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/03/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.14.7.1.2 Place the passenger cab interior lights in working order. 50 lx or 5 fc @ the cab floor.

Items must be corrected by: 03/04/2018

Elevator Name: GRAY (POL-SCI)

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy 3363806126

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
803 HAGGARD AVE
ELON, NC, 27244