

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 18004-73-3055 State Number 15307

]	EQUIPMENT INSPECTED		
State Number: 15307 Type of Unit: Pa		senger Floor to Floor: 1 to 2		
Capacity: 2100	Manuf: ASK		Speed: 95	
Landings: 2	Installed: 03/04/1994		Rope Size:	
Volts: 240	: 240 Complied: 03/04/1994		Entrances: 1	
OWNER		OCCUPANT		
GERALD L. FRANCIS CENTER (SMITHFIELD)		GERALD L. FRANCIS CENTER (SMITHFIELD)		
762 E HAGGARD AVE		762 E HAGGARD AVE		
ELON COLLEGE, NC, 27244		ELON COLLEGE, NC, 27244		
	IN	SPECTION INFORMATION		
Inspection Date 01/04/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
		VIOLATIONS		
8.6 Empty oil catch bucke	t in pit			
Items must be corrected by: 03/05/2018		Elevator Name: HEALTH SCIENCE		
Notify the Elevator Bureau in writ complainace with current codes.	ing on Corrected Violations Form	when the following corrections hav	e been made in order to br	ing your equipment into
Violations pointed out to: Jeremy			Inspector	
	To make changes to the invoice mailing address please call: 919-733-0372			
THIS IS NOT AN INVOICE	An invoice will be mailed to:	GERALD L. FRANCIS CENTER (SMITHFIELD) 16d to: 762 E HAGGARD AVE ELON COLLEGE, NC, 27244		