



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18010-48-2079**  
State Number  
**17363**

EQUIPMENT INSPECTED

State Number: <b>17363</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 11/24/1997	Rope Size:
Volts: 208	Complied: 02/03/1998	Entrances: 1
OWNER	OCCUPANT	
BLADEN CO. COMMUNITY COLLEGE	BLADEN CO. COMMUNITY COLLEGE	
7418 NC HWY 41N	7418 NC HWY 41N	
DUBLIN, NC, 28332	DUBLIN, NC, 28332	

INSPECTION INFORMATION

Inspection Date 01/10/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

2.7.3.4.1 Provide a self closing self-locking machine room / space door.

Items must be corrected by: 02/09/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: J.

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BLADEN CO. COMMUNITY COLLEGE  
7418 NC HWY 41N  
DUBLIN, NC, 28332